PORTABLE APPLIANCE TEST CERTIFIC

Name:	REECE DOWD	Contact Num:	
Test Site Address	29 Brean Avenue, Yardley, Solihull, B26 1JS		
Tester Manufacturer: SEAWARD		Model: 347A910	Serial No: N/A

Apliance No:	Description:	Location:	Manufacturer:	Serial N
1	Speaker	Mobile	RCF	N/
2	Speaker	Mobile	RCF	N/
3	Moving Head (Lights)	Mobile	Equinox	N/
4	Moving Head (Lights)	Mobile	Equinox	N/
5	Starlit Back Drop	Mobile	LEDJ	N/
6	Midi Controller	Mobile	Pioneer	N/
7	Wireless Microphone	Mobile	Audio Technica	N/
8	Smoke Machine	Mobile	Chauvet DJ	N/
9	Laptop	Mobile	Apple	N/
10	Bubble Machine	Mobile	American DJ	N/
11	Bubble Machine	Mobile	Chauvet DJ	N/
12	Bouncy Castle Blower	Mobile	Gibbons	N/
13	Bouncy Castle Blower	Mobile	Gibbons	N/
14	Foam Machine	Mobile	Master Blaster	N/
15	Snow Machine	Mobile	Commercial	11
16	Snow Machine	Mobile	Commercial	11
17	Confetti Cannon	Mobile	Commercial	11
18	Confetti Cannon	Mobile	Commercial	11
19	Photo Printer	Mobile	Mitsubishi	N/
20	Touch Screen	Mobile	Photobooth.co.uk	N/
21	Portable Hard Drive	Mobile	Photobooth.co.uk	N/
22	Photo Booth Lights	Mobile	B&Q	N/
23	42 INCH TV	Mobile	SAMSUNG	N/
24	42 INCH TV	Mobile	SAMSUNG	N/
25	16FT STARLIT DANCE FLOOR	Mobile	PROLIGHT	N/
26	DRY ICE MACHINE	Mobile	CHAUVET	N/

:ATE				RD TESTING		
7472324071		Date Of Test:		10/01/2024		
		Next Test Date:		10/01/2025		
		Engineer:		Reece Dowd		
\		Date Calibrated:		N/A		
Model:	Class (1,2,3)	Visual (Pass / Fail)	Fuse (Amps)	Test Type (26A, 8A, 100mA)	Earth Bond	Ins
/A	1	PASS	13	26A	0.04	>20
/A	1	PASS	13	26A	0.04	>20
/A	1	PASS	13	26A	0.06	>20
/A	1	PASS	13	26A	0.05	>20
/A	1	PASS	13	26A	0.04	>20
/A	1	PASS	13	26A	0.06	>20
/A	1	PASS	13	26A	0.05	>20
/A	1	PASS	13	26A	0.05	>20
/A	1	PASS	3	N/A	N/A	>20
/A	1	PASS	13	26A	0.06	>20
/A	1	PASS	13	26A	0.04	>20
/A	1	PASS	13	26A	0.06	>20
/A	1	PASS	13	26A	0.04	>20
/A	1	PASS	13	26A	0.05	>20
11	1	PASS	13	26A	0.06	>20
12	1	PASS	13	26A	0.04	>20
11	2	PASS	13	26A	0.05	>20
12	3	PASS	13	26A	0.05	>20
/A	4	PASS	3	N/A	N/A	>20
/A	5	PASS	3	N/A	N/A	>20
/A	6	PASS	3	N/A	N/A	>20
/A	7	PASS	3	N/A	N/A	>20
/A	2	PASS	13	26A	0.05	>20
/A	3	PASS	13	26A	0.05	>20
/A	7	PASS	13	26A	0.05	>20
/A	2	PASS	13	26A	0.05	>20

Flash	Load / Leak	Comments	Pass	Fail
N/A	N/A	GOOD	PASS	
N/A	0.07	GOOD	PASS	
N/A	0.06	GOOD	PASS	
N/A	N/A	GOOD	PASS	
N/A	0.07	GOOD	PASS	
N/A	0.08	GOOD	PASS	
N/A	0.06	GOOD	PASS	
N/A	0.07	GOOD	PASS	
N/A	N/A	GOOD	PASS	
N/A	0.07	GOOD	PASS	
N/A	0.06	GOOD	PASS	
N/A	0.07	GOOD	PASS	
N/A	0.06	GOOD	PASS	
N/A	0.06	GOOD	PASS	
N/A	0.07	GOOD	PASS	
N/A	0.05	GOOD	PASS	
N/A	0.06	GOOD	PASS	
N/A	0.06	GOOD	PASS	
N/A	N/A	GOOD	PASS	
N/A	N/A	GOOD	PASS	
N/A	N/A	GOOD	PASS	
N/A	N/A	GOOD	PASS	
N/A	0.06	GOOD	PASS	
N/A	0.06	GOOD	PASS	
N/A	0.06	GOOD	PASS	
N/A	0.06	GOOD		